

ADDENDUM NO. 2
TO THE
PLANS AND SPECIFICATIONS
FOR THE
CENTENNIAL CROSSING
LIFT STATION AND FORCE MAIN PROJECT
FOR THE
CITY OF PLYMOUTH
MARSHALL COUNTY, INDIANA

MEI PROJECT NO. 2019102-00
Issue Date: July 7, 2020

This addendum forms part of the Contract Documents and modifies the original Contract Documents as noted below. Acknowledge receipt of this Addendum by inserting the number and issue date of this addendum in the blank space provided on the Attachment to Form 96 included in the bidding documents.

The following items shall amend the specifications for the above project and shall take precedence over items in conflict herein. This Addendum is hereby made a part of the contract documents.

Item No. 1: Reference Specifications, Bid Proposal

Delete: Original bid set specification bid proposal form.

Replace With: Attached bid proposal form.

Clarification: Added a mandatory Alternate Bid #1 to allow a Fiberglass Wetwell and attached Valve Vault option in lieu of the concrete as depicted on the plans. The Contractor is instructed to circle ADD or DEDUCT on the bid proposal when submitting their bid. The Owner reserves the right to award the project based on the base bid submitted or the alternate bid item with the base bid as described.

Item No. 2: Reference Addendum #1, Item No. 10

Change: Wet well and valve vault shall be concrete as indicated on plans and described in the specifications. Fiberglass construction shall not be considered an approved equal.

To Read: Contractor shall be allowed to provide and install a fiberglass reinforced polyethylene (FRP) wet well and attached valve vault in lieu of concrete as shown on plans. The FRP option shall be dimensionally coordinated with the supplier during construction, if approved by Owner and Engineer. The FRP product shall be provided by AK Industries, no equal. Contact Seth Ferguson (574) 936-6022 prior to bid.



Direct all questions relating to the above project to:

MIDWESTERN ENGINEERS, INC.

A handwritten signature in black ink that reads "Mark M. Sullivan".

Mark M. Sullivan, P.E.
Senior Project Engineer, CEO
(317) 334-0262

msullivan@midwesterneng.com

**BID PROPOSAL
FOR
CENTENNIAL CROSSING
LIFT STATION AND FORCE MAIN
FOR THE
CITY OF PLYMOUTH
MARSHALL COUNTY, INDIANA**

BASE BID

ITEM NO.	DESCRIPTION	ESTIMATED QUANTITY	UNIT	UNIT PRICE	TOTAL PRICE
1.	Mobilization / Demobilization	1	LS	\$ _____	\$ _____
2.	Force Main - 6" - Directional Drill	750	LF	\$ _____	\$ _____
3.	Force Main - 6" - Open Cut	300	LF	\$ _____	\$ _____
4.	8" Gravity Sewer	30	LF	\$ _____	\$ _____
5.	New Sanitary Manhole with Force Main Connection	1	LS	\$ _____	\$ _____
6.	Connect Force Main to Existing Manhole	1	LS	\$ _____	\$ _____
7.	Lift Station / Valve Vault	1	LS	\$ _____	\$ _____
8.	Electrical	1	LS	\$ _____	\$ _____
9.	Surface Restoration	1	LS	\$ _____	\$ _____
10.	SCADA and Duplex Pump Control Panel	1	LS	\$ _____	\$ _____
11.	Traffic and Erosion Control	1	LS	\$ _____	\$ _____
12.	Tracer Wire Locate Terminals	4	EA	\$ _____	\$ _____
TOTAL BASE BID					\$ _____ <i>(Figures)</i>

Mandatory Alternate Bid. No. 1 : Fiberglass wetwell and attached valve vault

ITEM NO.	DESCRIPTION	ESTIMATED QUANTITY	UNIT	UNIT PRICE	TOTAL PRICE
1	Fiberglass wetwell and attached valve vault in lieu of concrete.	1	LS	_____	_____
ADD OR DEDUCT FROM BASE BID (CIRCLE ONE)				ADD DEDUCT	
Total Alternate Bid No. 1					_____

(Words)

NOTE: THE BASIS OF AWARD MAY CONSIDER EITHER THE BASE BID OR THE BASE BID WITH ALTERNATE BID NO. 1 IN THE DETERMINATION OF THE LOWEST RESPONSIBLE AND RESPONSIVE BIDDER.

Respectfully submitted:

Signature

Address

Title

Date

(SEAL) (If BID is by a Corporation)

License No. (if applicable)