

**ADDENDUM NO. 1
TO THE
PLANS AND SPECIFICATIONS
FOR
WATER SYSTEM IMPROVEMENTS
WATER TREATMENT PLANT
FILTER MEDIA REPLACEMENT
FOR THE
CITY OF WASHINGTON
DAVISS COUNTY, INDIANA**

MEI PROJECT NO. 2024042-03


March 26, 2024

The following items shall amend, clarify and/or correct plans and/or specifications for the above project and shall take precedence over items in conflict herein:

ITEM NO. 1: **Reference Specifications, MECHANICAL SPECIFICATIONS, M-3 FILTER NO. 5, 6, 7, AND 8 FILTER MEDIA REPLACEMENT, INSTALLATION OF NEW NOZZLES AND EXISTING NOZZLE REMOVAL (OWNER RETAINS NOZZLES), PARAGRAPH II NOZZLES REMOVAL, INSTALLATION NEW NOZZLES AND O-RINGS BY CONTRACTOR AND RETAINED BY OWNER, Page M-4**

ADD: The following sentence to the end of the first paragraph:
"The Contractor shall provide and install nine hundred (900) new nozzles and O-rings."

Respectfully Submitted,
MIDWESTERN ENGINEERS, INC.



Richard A. Burch, P.E.
Sr. Project Engineer

RAB/amc